



FOOD TRUCK INSPECTION CHECKLIST

<input type="checkbox"/>	CO Detector - Must be UL Listed and mounted inside the unit
<input type="checkbox"/>	CO Detector Monthly Check-off Sheet (Initial sheet from JFRD Fire Prevention)
<input type="checkbox"/>	Gas Leak Detector - <i>"Handheld LP Gas Leak Detector" - if there any questions on type, reach out to JFRD Fire Prevention with link and description prior to purchase</i>
<input type="checkbox"/>	Gas Leak Detector Monthly Check-off Sheet (Initial sheet from JFRD Fire Prevention)
<input type="checkbox"/>	Hood Cleaning - Hood cleaned and tagged within the last 6 months. <i>Cannot be within 2 weeks of expiration.</i>
<input type="checkbox"/>	Hood Suppression System - ANSI/UL 300 systems. Hood tagged within the last 6 months. <i>Cannot be within 2 weeks of expiration.</i>
<input type="checkbox"/>	Gas Cylinders Certification - Completed annually by an approved company with expertise in the installation, inspection and maintenance of LP-gas systems. <i>Cannot be within 2 weeks of expiration. "Propane Supplier in Jacksonville, FL"</i>
<input type="checkbox"/>	Fire Extinguisher - Dry Chem - Expires annually. Tagged by a licensed company. <i>Minimum size - 2a:10bc. Must be mounted. Cannot be within 2 weeks of expiration.</i>
<input type="checkbox"/>	Fire Extinguisher - Class-K - Expires annually. Tagged by a licensed company. <i>Must be mounted. Cannot be within 2 weeks of expiration.</i>
<input type="checkbox"/>	Gas Cylinders secured - Mounted securely on vehicle
<input type="checkbox"/>	Generator secured - Mounted securely on vehicle
<input type="checkbox"/>	Wiring - Installed in accordance with NFPA 70.
	No open spots in breaker box.
	No exposed wires. All wires must be inside conduit.
	All electrical boxes must be covered.
	All light switches and electrical outlets are required to have covers.
	All extension cords free of splices, frays, and loose connections.
<input type="checkbox"/>	Wheel Chocks - 2 are required to prevent unit from moving.
<input type="checkbox"/>	No excessive grease build up inside of unit.
<input type="checkbox"/>	Updated trailer registration and tag
<input type="checkbox"/>	Valid Drivers License